



# **POWER QUALITY**

***Initiatives by BESCOM***

**Due to increase in usage of non-linear loads, there is distortion of Power quality.**

**Poor Power quality may be due to:**

- ❑ Drop in system voltage because of lengthy lines/over loaded lines – Improper planning.**
- ❑ Drawl of more reactive power resulting in increased technical losses and poor voltage profile.**
- ❑ Injection of current Harmonics by consumer loads.**

**The non-linear behaviour of such loads causes distortion of current waveform, which in turn distorts the voltage waveform. It is a challenge for the distribution utilities to overcome such problems and they can be mitigated by:**

- ❑ Improving the voltage profile with proper planning.**
- ❑ Providing dynamic reactive power compensation.**
- ❑ Conducting studies and taking suitable action to mitigate the harmonics.**

**Now, under SRTPV, solar power is injected to distribution grid at HT and LT level.**

**At 7 SRTPV installations of 100kwP and above, harmonics level and DC current injection study was conducted with the assistance of PRDC and the observations of the study report are:**

- At some locations, though some of the harmonics levels are predominant/ exceeds the limits for shorter period, they are within the specified limits.**

**At one location, 5th voltage harmonic distortion violated continuously the specified limit for numerous times during non-solar period.**

- ❑ Total distortion are within limits.**
- ❑ During measurement of DC current injection, the solar generation was not at full capacity and the limits were within the specified limit.**
- ❑ The DC current injection may exceed the limit when the system operates at rated capacity.**

**Similar studies were conducted at 10 different category HT installations and at 4 installations following observations were made:**

- ❑ 5th harmonic Voltage distortion exceeds the IEEE specified limit of 3% by 85%.**
- ❑ 5th harmonic voltage distortion exceed the IEEE specified limit of 3% by 43% and the disturbance has occurred at several instances and exceeds for a maximum continuous duration of 250 minutes.**

**The Total harmonic distortion is 14.41% and is just below the IEEE specified limit of 15%**

- At one location, 2<sup>nd</sup> to 8<sup>th</sup> order voltage harmonic distortions exceeds the IEEE limit by 378%, 210%, 100%, 47%, 35%, 1% and 8% respectively.**

**At the same installation, 2<sup>nd</sup> and 4<sup>th</sup> order current harmonics exceeds the IEEE specified limit by 64% and 23% respectively.**

**The study warrants BESCOM to move forward and BESCOM planned to conduct few more such studies and to:**

- ❑ Insist for Harmonic filters**
- ❑ To have a penalty clause**
- ❑ To Measure/record Harmonics.**



**In addition, BESCOM has taken steps to identify some of the nodes where reactive power drawl is more and an initial study has already been conducted at one of the node.**

**Now it is the high time to plan for dynamic reactive power compensation which will:**

- ❑ Enhance the network capability.**
- ❑ Improve voltage profile.**
- ❑ Less capital investment.**
- ❑ Reduce technical losses.**

- ❑ **Implementation of DAS in major cities will also help in improving the power quality by keeping the 11kV ring system open at right location with prior study.**
- ❑ **Identifying the DTs which are overloaded/ not at load centers with proper planning and taking suitable action.**



*THANK YOU*

# Limits :IEEE 519-2014

## Voltage distortion limits

<b>Bus voltage at Point of Common Connection(PCC)</b>	<b>% Individual voltage distortion</b>	<b>% Total voltage distortion THD</b>
<b>1.0 kV and below</b>	<b>5.0</b>	<b>8.0</b>
<b>Above 1.0kV through 69 kV</b>	<b>3.0</b>	<b>5.0</b>
<b>Above 69 kV through 161kV</b>	<b>1.5</b>	<b>2.5</b>
<b>Above 161kV</b>	<b>1.0</b>	<b>1.5</b>

# Limits :IEEE 519-2014

**Current distortion limits for systems rated 120V through 69kV:**

<b>Maximum harmonic current distortion in percentage of <math>I_L</math></b>						
<b>Individual harmonic order(odd harmonics)</b>						
<b><math>I_{SC}/I_L</math></b>	<b><math>3 \leq h &lt; 11</math></b>	<b><math>11 \leq h &lt; 17</math></b>	<b><math>17 \leq h &lt; 23</math></b>	<b><math>23 \leq h &lt; 35</math></b>	<b><math>35 \leq h &lt; 50</math></b>	<b>TDD</b>
<b>&lt;20</b>	<b>4.0</b>	<b>2.0</b>	<b>1.5</b>	<b>0.6</b>	<b>0.3</b>	<b>5.0</b>
<b>20&lt;50</b>	<b>7.0</b>	<b>3.5</b>	<b>2.5</b>	<b>1.0</b>	<b>0.5</b>	<b>8.0</b>
<b>50&lt;100</b>	<b>10.0</b>	<b>4.5</b>	<b>4.0</b>	<b>1.5</b>	<b>0.7</b>	<b>12.0</b>
<b>100&lt;1000</b>	<b>12.0</b>	<b>5.5</b>	<b>5.0</b>	<b>2.0</b>	<b>1.0</b>	<b>15.0</b>
<b>&gt;1000</b>	<b>15.0</b>	<b>7.0</b>	<b>6.0</b>	<b>2.5</b>	<b>14</b>	<b>20.0</b>
<b>Even harmonics distortions are limited to 25% of the odd harmonic limits.</b>						
<b>TDD = Total Demand Distortion</b>						